iftROSENHEIM

Classification Report

Number 18-003235-PR02 (NW-A01-0203-en-01)

Owner Europa Profil Aluminio S.A.

56th Klm National Highway

Athens - Lamia 32011 Innofita Viotas

Greece

Product Lift-sliding door, scheme D

Designation System: EUROPA A40SL

Shipping name: EUROPA A40 SL DOUBLE SLIDING

Details Manufacturer Europa Profil Aluminio S.A., - Innofita Viotas;

Material Aluminium system with thermal break; Type of opening Lifting sliding; Opening direction Sash right before sash left;

Overall dimensions (W x H) 2500 mm x 2400 mm

Special features Test sequence. Construction with visible internal drainage.

The vapour pressure equalisation of the glazing rebate has to be ensured. The strength, durability and material compatibility of the adhesive system was not part of the test

and is tested separately.

Result

Operating forces according to EN 13115:2001-07



Class: 1

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C1/B2

Watertightness according to EN 12208:1999-11



Class: E900

ift Rosenheim 19.02.2019

Thomas Stefan, Dipl.-Ing. (FH) Head of Testing Department Building Component Testing Dimitrios Moustakidis, MSc, Dipl.-Ing. Operating Testing Officer Building Component Testing



EN 14351-1:2006+A2:2016-09
*) and corresponding national versions e.g. DIN EN)

Test report: 18-003235-PR02 PB-A01-0203-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.

When using this document the upto-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft ID: BD4-68265



